ADDENDUM No. 5

TO:

ALL BIDDERS

FROM:

CITY OF HIALEAH

ITB#:

2016/17-9500-00-006

RE:

ITB - PUMP STATION 106 IMPROVEMENTS

DATE:

May 8, 2017

The original contract documents for the entitled: ITB – PUMP STATION 106 IMPROVEMENTS needs to be amended as noted in this Addendum No. 5.

This Addendum No. 5 consists of 1 typed page, 0 attachments, and 1 addendum receipt form (ARF). All other items and conditions of the original Contract Documents shall remain unchanged. This Addendum shall become a part of the Contract Documents.

Approved for issue:

_ Date: May 8, 2017

Luis A. Suarez - Acting Purchasing Manager

ACKNOWLEDGMENT

Receipt of this Addendum No. 5 shall be acknowledged in the space provided on the ADDENDUM RECEIPT form – ARF (Copy attached) now a part of the Contract Documents to be faxed immediately to the City of Hialeah Purchasing Division (305) 883-5871 and submitted with sealed bids.

GENERAL CLARIFICATIONS

- 1. Contractor is responsible for the safe and proper removal of the existing 2,000 gallon above ground diesel fuel storage tank in accordance with all governing regulatory requirements. The Contractor shall obtain a Storage Tank System Removal Permit, and hire a Pollutant System Specialty Contractor as required to comply with all permit requirements. A Tank Closure Assessment Report shall be submitted to DERM within 60 days of removals.
- Existing generator slab, fuel storage tank slab, and booster pump slabs to be demolished as shown on C01 are approximately ±36 inches thick. Contractor shall price and plan for demolition and removal of these slabs accordingly.

CHANGES IN THE CONTRACT DOCUMENTS:

The deadline for submitting bids is hereby moved to 3:00 p.m. on <u>Thursday</u>, <u>May 11, 2017</u>. All bids must be submitted by this deadline.

Addendum No. 5 Page 1

END OF ADDENUM No. 5

CITY OF HIALEAH

ITB - PUMP STATION 106 IMPROVEMENTS

ADDENDUM No. 5

CONTRACTOR'S NAME		
ADDRESS		
PHONE NO.		
CONTACT NAME	SIGNATURE	
	S RECEIPT OF THE FOLLOWING ADDEND ed immediately to the City of Hialeah at (30	
ADDENDUM	SIGNATURE	<u>DATE</u>
5		<u> </u>